Ewing Township (1102)

Introduction

This municipal chapter is an element of the Mercer County Wastewater Management Plan prepared by the Mercer County Planning Division in accordance with N.J.A.C. 7:15.

Ewing Township is located in the eastern portion of Mercer County and encompasses approximately 15 square miles. The Township is suburban. Approximately 80 percent of the largest parcels are publicly owned. The primary stream networks run through suburban areas to join larger waterways and the Delaware River and canal system. Approximately 6 percent of the Township is comprised of public parks and preserved open space. These areas include large regional parks and golf courses, and smaller municipal parks and community centers. The remaining land within the Township consists mainly of residential housing and commercial uses, including The College of New Jersey campus and several large corporate campuses, the Trenton-Mercer Airport, and a private golf course. The dense residential areas are located primarily on the east side of the Township clustered around Route 31, the primary north-south transportation corridor. The larger parcels of land are located in the western portion of the Township. The Township zoning designations are shown on Map 4M.

Federal and state highways, including I-95, Route 29, Route 31, and several county roads such as CR622, and CR634, also provide for a variety of land use. Route 31 is identified in the Mercer County Master Plan as a growth corridor. Redevelopment areas are located along CR622 and CR634. The Septa R3 rail line runs south through the Township from the West Trenton station and continues through Pennsylvania to Philadelphia.

The 2005 DVRPC (Delaware Valley Regional Planning Commission) population projection estimates Ewing's population in 2010 to be 36,977 up from the 2005 population of 36,137. The 2007 DVRPC population projection estimates a decrease in Ewing's 2010 population to be 37,021. The US Census estimates f

Following are some important considerations for this municipality with respect to wastewater management planning:

Ewing Township is considered a non-urban municipality.

In this document the following terms may be used:

EDUs - Equivalent Dwelling Units - a measure where one unit is equivalent to wastewater effluent from one dwelling unit. NJDEP defines a dwelling unit to mean any building or portion of a building, permanent or temporary, used or proposed to be used as a residence either seasonally or throughout the year. Most often, EDU is used in reference to a single family home.

gpd – gallons per day, a unit of flow measurement.

GW - groundwater

HUC11 - Hydrologic Unit Code consisting of 11 digits – a United States Geological Survey (USGS) standard designation for subwatersheds delineated based on topography.

Individual Subsurface Disposal System (ISSDS) – means a system for the disposal of sanitary sewage into the ground, which is designed and constructed to treat sanitary sewage in a manner that will retain most of the settleable solids in a septic tank and discharge the liquid effluent to a disposal field.

mgd – million gallons per day, a unit of flow measurement.

Nitrate Dilution Model (NDM) – The NDM is required by NJDEP and follows the calculations methodology developed by the New Jersey Geological Service (NJGS). The NDM uses the soils type (SSURGO (NRCS) digital soils GIS layer revised by DEP) to estimate the minimum lot size needed to provide enough recharge to dilute nitrate to a specified target. This method is intended to be a guide for estimating the impact of nitrate from septic tanks on groundwater quality. The NDM uses the minimum lot size to calculate the number of EDUs possible for a given area.

Non-discharge areas - areas where additional wastewater generation and/or discharge are prohibited.

Non-urban municipality – any municipality not officially designated as an urban municipality

Septic Area – means an area to be served by systems for the disposal of sanitary sewage into the ground, which is designed and constructed to treat sanitary sewage in a manner that will retain most of the settleable solids in a septic tank and discharge the liquid effluent to a disposal field. Planning flows for septic areas are 2,000 gpd or less.

Service Areas – areas designated as wastewater discharge to permitted surface water facilities, groundwater facilities, ISSDS, or septic

Sewer Service Area (SSA) – represents the area to be served by a centralized treatment facility.

STP - Sewage Treatment Plant

SW – surface water

Undeveloped/under developed – areas within the existing or future sewer service area that could be developed

WMP – Wastewater Management Plan

WPCF - Water Pollution Control Facility

WPCP - Water Pollution Control Plant

WTF - Water Treatment Facility

WWTP - Wastewater Treatment Plant

Existing Infrastructure

The existing wastewater collection and conveyance infrastructure within this municipality consists of the following:

- Collection System The majority of Ewing Township is largely developed with the
 exception of few remaining parcels within the Township. The collection system and
 associated trunk sewers convey flow from these populated areas to the Ewing Lawrence
 Sewerage Authority.
- Pumping Stations Ewing Township, ELSA owns and operates seven (7) pumping stations within the municipal boundaries, and there are a number of privately owned and

operated pumping stations serving residential developments and school and office campuses within Ewing Township.

The existing major wastewater treatment facilities located within the municipality include:

 No existing major wastewater treatment facility is currently located within the municipality.

Tables 1a and 1b include additional minor facilities in Ewing Township regulated through NJDEP that have individual New Jersey Pollutant Discharge Elimination System (NJPDES) discharge permits. Table 1a shows facilities which are indicated as discharge to groundwater (DGW). Table 1b shows facilities which are indicated as discharge to surface water.

The NJDEP, Division of Land Use Management, provided the data for Tables 1a and 1b.

The existing treatment facilities, if any, are illustrated on Map 2M.

Mercer County
Wastewater Management Plan

Volume II - Municipal Chapters
Ewing Township

Table 1a: NJPDES (DGW) Permitted Facilities within Ewing Township

NJPDES Permit Number	Facility Name	Permit Program Code	Receiving Stream or Aquifer	Classification	Permittee	Contact Organization Name	Block	Lot	Permitted Flow (MGD)	Existing Flow (MGD)	Future Flow (MGD)	Discharge Category
None												

Mercer County	Volume II - Municipal Chapters
Wastewater Management Plan	Ewing Township

Table 1b: NJPDES (DSW) Permitted Facilities within Ewing Township

	NJPDES Permit Number	Facility Name	Permit Program Code	Receiving Stream or Aquifer	Classification	Permittee	Contact Organization Name	Block	Lot	Permitted Flow (MGD)	Existing Flow (MGD)	Future Flow (MGD)	Discharge Category
No	ne												

Environmental Features

Ewing Township is bordered by the Delaware River, Hopewell Township, Lawrence Township, and the City of Trenton. The Township contains protected open space and recreational areas including but not limited to the following:

- Moody Park
- Banchoff Park
- Armstrong Park
- Temple Park
- Ackerman Park
- Mountainview Golf Course
- D&R Canal Towpath

Several streams run throughout the Township. The Shabakunk runs north-south in the eastern portion of the Township. The streams found in the western portion of the Township runs into the Delaware River forming a portion of the Township's western boundary.

Major streams include Ewing Creek, Gold Run, Jacobs Creek, Little Shabakunk Creek, and Shabakunk Creek.

Delineation of Service Areas and Planning Integration

Sewer Service Areas

Following are the sewer service areas within Ewing Township. Existing areas served and future SSAs are shown on Maps 2M and 3M, respectively. The facilities providing treatment to these service areas have an associated facilities table in the Appendix.

 Ewing Lawrence Sewerage Authority (NJPDES NJ0024759) – This SSA serves the entire Township.

An explanation of the mapping method used to delineate the SSA is included in Appendix A to this chapter.

Septic Areas (ISSDS)

Individual subsurface sewage disposal systems (ISSDSs) consist of those areas with planning flows 2,000 gallons per day or less (i.e. residential septic systems) that are neither designated for sewer service nor as non-discharge areas. These areas can be seen in Maps 2M and 3M.

Future Wastewater Demand and Facilities

For the purposes of evaluating capacity and future sanitary flow rates, the full build-out of undeveloped or underdeveloped land in the Township was derived from existing zoning and the development potential of land parcels within the Township. The results of the build-out were compared to the permitted treatment capacity of major wastewater treatment facilities. This analysis is not required for the minor facilities.

The County used CommunityViz, a land use planning software package offered through Placeways, LLC. CommunityViz is an extension for ESRI's ArcGIS platform that uses existing zoning information to estimate future development. CommunityViz uses zoning data such as minimum lot size and set back requirements to evaluate potential number of future residential units or square feet of commercial space on individual parcels or within the municipality.

The County has identified a category of service indicated as "open with facilities". This category was created in response to a number of comments received from municipalities to include recreational lands, many purchased through public funding, in the Future SSA. The requests pertain to open space properties that currently have support facilities or may have them in the future. The intent of this service type category is to account for up to 2,000 gpd of wastewater generation from these parcels, while recognizing they will continue to function as municipal open space and recreational facilities. The estimated flow has been included in the capacity analysis for the facility serving the closest sewer service area. This category gives municipalities flexibility in planning for essential facilities that support existing and future recreational programming at the local level.

Sewer Service Area Wastewater Capacity Analysis

Table 2a presents the results of the Build-out Analysis within the SSA indicated above.

Table 2a: Ewing Township Build-out Table (SSAs)

^{*} Facility Tables are located in Appendix D of the County WMP document. See ELSA Facility Table for current build-out flows by municipality.

**Total Existing Flow is taken from DMR data February 2011 through January 2012.

Treatment Works Approvals (TWAs) approved by NJDEP for unconnected projects within Ewing Township consist of the following:

Table 2b – Treatment Works Approvals

TWA	Facility	Unconnected Flow (mgd)
Opus East (built)	Ewing-Lawrence SA	0.0472
Gardens at Birmingham	Ewing-Lawrence SA	0.0115
Bear Tavern Greene	Ewing-Lawrence SA	0.0698
Total		0.1285

The capacity of the ELSA STP is shown in the Facility Table. The facility provides treatment on a "first-come, first-serve" (FCFS) basis. ELSA has no municipal allocations.

Undeveloped and underdeveloped parcels are shown on Map 3M.

Septic Area Wastewater Capacity Analysis

Table 3 presents the results of the Build-out Analysis within the ISSDS. The ISSDS is shown on Map 3M.

The breakdown by HUC11 subwatershed is shown below.

Table 3 - Ewing Township Build-out by HUC

	Build-out Potential (Ed				
HUC	Using Nitrate Dilution Model	Under Municipal Zoning	Surplus/Deficit		
02040105210	45.9	0	46		
02040105240	37.1	9.0	28		

Table 3 shows the variation in build-out results based on existing zoning as compared to the potential EDUs predicted by the Nitrate Dilution Model (NDM). The zoning based build-out and the NDM should be run on a HUC11 basis to determine if the entire HUC has sufficient nitrate dilution capacity to accommodate full zoning build-out.

For Table 3, equivalent dwelling units were calculated using the following formula: [potential residential flow (gpd) + potential non-residential flow (gpd)]/500 gpd/EDU. Potential non-residential flow in septic areas was estimated using existing zoning criteria (e.g. FAR) and a flow factor of 0.125 gpd/square foot.

The Septic Area build-out capacity analysis for Ewing Township was based on the 2.0 mg/L statewide standard for the target concentration of nitrate in groundwater.

Following are the results of this analysis shown in table 3 for Ewing Township's portion of the HUC:

- For HUC 02040105210, no ISSDS parcels were present in the HUC. So, the Build-out Potential Under Municipal Zoning was zero. However, the Nitrate Dilution Model (NDM) was used to calculate the surplus dilutive capacity of parcels such as open space and environmentally sensitive areas that were not hydric. The calculated surplus can be used to offset deficits within the municipality and within this HUC on a regional basis.
- For all HUCs, the build-out results based on existing zoning are less than the number of
 potential EDUs generated by the NDM for septic capacity, and therefore, no further
 analysis of these HUCs will be required nor will any change in zoning be required.

A list of zoning codes and descriptions are included on Map 4M.

Appendix A – Basis for Service Area Delineations SSA (Sewer Service Area)

The SSA designation is for areas from which wastewater is designated to flow to a permitted wastewater treatment facility.

In assigning the SSA designations shown, several data sources were considered:

- Cross-Acceptance proceedings (2004)
- NJDEP's adopted SSA map for Mercer County (2006)
- NJDEP's draft SSA map for Mercer County (2008) including revised editions based on public comments received from December 2008 through March 2011; editions of the original 2008 map were reviewed periodically during this period once in June 2009, once in February 2010, and once in November 2010 prior to the NJDEP Public Meeting in December 2010.
- Data (such as collection system extent) obtained from municipalities or private entities.
- Existing TWA permits
- Sewer service areas provided by existing sewerage authorities and wastewater treatment facilities

Parcels that were within previous draft or adopted sewer service areas, or existing sewer service areas provided by sewerage authorities or wastewater facilities, were given the SSA designation, unless specific guidance was provided to remove them. In early 2010, the NJDEP issued Administrative Consent Order 2010-03. Subsequent to adoption of the ACO, all mapping followed the protocol established in the ACO.

Proximity to existing collection systems was considered if service for a given parcel was indeterminate based on other criteria.

Parcels with valid NJDEP Treatment Works Approvals (TWA) were automatically given a SSA designation.

Septic Areas (ISSDS)

The ISSDS designation represents those areas served by septic systems. For the purpose of mapping, the ISSDS designation also represents those areas that are not designated as any of the other categories (SSA or Open/Utility as described below).

Open & Utility (Open Space, Open with Facilities, Utility)

The Open & Utility designation identifies the following:

Open Space – Mercer County Planning Division maintains an open space layer. The
county boundary is the layer's geographic extent. The open space layer is developed
from several sources including a county-owned land inventory, Green Acres ROSI,
preserved farmland inventory, municipal open space inventories, and state and nonprofit open space inventories. The open space layer served as the basis for identifying
undevelopable land designated through the Plan as Municipal, County, or State Land,
Deed Restricted properties, Conservation Easements, and certain lands overseen by
non-profit entities.

- Open with Facilities This category was created in response to comments received from municipalities to include recreational lands in the Future SSA. These open space properties currently have support facilities or may have them in the future. This category gives municipalities flexibility in planning for essential facilities that support existing and future recreational programming at the local level.
- Utility tax assessment data was used to identify lands owned by public utilities.

This designation indicates that these parcels are undevelopable, except for instances where public programs require the construction of public facilities.

Environmentally Sensitive Areas

The Environmentally Sensitive Areas (ESAs) designation applies to those areas that have been mapped as such by NJDEP. They consist of the following:

- Wetlands areas based on NJDEP's Land Use/Land Cover feature class (2002)
- Stream corridors areas which incorporate the appropriate buffer along surface waters based on NJDEP's stream classification (2008)
- Natural Heritage Priority Sites areas of critical importance due to the presence of rare plant species and ecological communities (2007)
- Landscape Project Areas (Rank 3, 4, and 5) areas representing wildlife habitat
 mapping for community planning and endangered species conservation. Rank 3 is
 associated with NJ State threatened species. Rank 4 is associated with NJ State
 endangered species. Rank 5 is associated with Federal threatened or endangered
 species (2007). The Landscape Project version used for this WMP was v2.1.

Methodology

The following methodology was employed to designate all parcels within Mercer County as either SSA or ISSDS, except for parcels designated as Open/Open with Facilities/Utility as described above. The following is the general methodology used for preparing the Draft SSA Map.

- 1. Parcels were evaluated to determine if:
 - a. It was designated under the Mercer County's open space inventory.
 - b. It was owned by a public utility.

Any parcels falling within the above categories were designated as Open/Utility.

- 2. The remaining parcels were evaluated to determine if they were part of previous approved SSA. If so, these parcels were designated SSA, unless directed otherwise by NJDEP, Mercer County, or the Municipality.
- 3. The remaining parcels not designated as previously part of an SSA were also evaluated to determine if any existing wastewater generating structures were present onsite using Mercer County's building footprint (January 2009) layer and aerial photography (2007). County staff further reviewed these parcels with more current aerial photography (2009). COAH and local approvals were also considered in this evaluation. If sewage generating potential was identified, the parcel was further evaluated to determine if it was readily

sewerable by an existing collection system without extending it. If this was the case, the parcel was designated as SSA unless:

- a. A significant portion of the parcel is undeveloped and falls within the constrained boundary AND
- b. Comments were received from NJDEP indicating the constrained portion of the parcel was to be excluded from the SSA.

In cases where a) and b) above apply, the parcel was split along the Constrained boundary. In this case, the portion of the parcel within the Constrained boundary was designated ISSDS and the remaining unconstrained portion was designated SSA.

- 4. For parcels not addressed under 1, 2, or 3 above, any vacant lands were evaluated to determine if it was readily sewerable by an existing collection system without extending it. If this was the case, the parcel was designated as SSA unless:
 - a. Comments were received from NJDEP, Mercer County, or the Municipality indicating the subject parcel should be excluded from SSA category. If such was the case, the parcel was designated ISSDS.
 - b. The parcel was constrained in whole or in part by Environmentally Sensitive Areas (ESA). If this was the case, the portion of the parcel within the constrained boundary was designated as ISSDS and the remaining unconstrained portion was designated as SSA.
- 5. Parcels that were not designated under 1, 2, 3, or 4 above were designated as ISSDS.